

MAINTENANCE ELIGIBILITY PROGRAM (MEP)

MHFD Referral Review Comments

For Internal MHFD Use Only.	
MEP ID:	106644
Submittal ID:	10004525
MEP Phase:	Referral

Date: March 31, 2020

To:

Via email

RE: MHFD Referral Review Comments

Project Name:	Crown Point Parker Adventist Salt Shed
Location:	SE of Parker Rd at Crown Crest Blvd – SE side of Hospital parking lot
Drainageway:	Cherry Creek

This letter is in response to the request for our comments concerning the referenced project. We have reviewed this proposal only as it relates to maintenance eligibility of major drainage features. It is our understanding these improvements will not generate a new outfall into the receiving creek, therefore, this project is:

- Not applicable; referenced project does not include any proposed MEP features, rezoning, etc.

We have, however, provided additional comments as a courtesy relating to the proposed onsite stormwater management.

1. On the Construction Drawings the swale on the east has a starting elevation higher than the Shed's FFE. What structures/berms will be used to ensure the salt is contained during large storm events?
2. As salinity levels in both soil and water are critical for environmental stability, please provide an Emergency Operations Plan providing more information on salt containment. It appears that the runoff from the shed would discharge into the creek untreated. How will water quality be maintained? Please include any necessary measures to ensure contaminants do not alter the characteristics of Cherry Creek.

We appreciate the opportunity to review this application and look forward to working with you as the drainage design progresses for any proposed developments.

Please feel free to contact me with any questions or concerns.

Sincerely,



Kurt Bauer, P.E., CFM

Project Manager, Watershed Services