

EXHIBIT F



Parker Water & Sanitation District (PWSD)
Landscape/Irrigation Worksheet

updated 9/24/07

Project Name: Slim Chickens

Landscape/Irrigation Tap address (physical location of tap) SWC of S. Parker Rd and E. Pine Lane

Landscape Area	High Water TURF (6,000sf = 1 SFE)	Low Water Native Grass and Spray Shrubs & Perennials (10,000sf = 1 SFE)	Drip Irrigated area (20,000sf = 1 SFE)	Non-Irrigated area (calculated)	Sub-Total of Areas	PWSD one SFE per 6000	SFE Requirement (Sub-Total Calculation divided by 6000 = requirement)
Area #1	$\frac{0 \text{ sf} \times 1 =}{0}$	$\frac{0 \text{ sf} \times .6 =}{0}$	$\frac{7,346 \text{ sf} \times .3 =}{2,204}$	$\frac{0 \text{ sf} \times 0 =}{0}$	<u>2,204</u> sf	6,000	<u>0.37</u> SFE's

Worksheet Completed by: Lawrance M. Lesser
 Company: Evergreen Design Group
 Address: 1755 Telstar Dr., Suite 300
 Phone #: Colorado Springs, CO 80920

Owner/Developer: _____
 Attn: _____
 Billing Address: _____
 Phone #: _____

ET Controller (with Rain Sensor)

Manufacturer: RainBird
 Model number: ESP4ME3 w/LNK WiFi module

Tap Size Requirements:
 0 - 1 SFE's requires a 3/4-inch tap
 1.1 - 2.0 SFE's requires a 1-inch tap
 2.1 - 4.0 SFE's requires a 1 1/2-inch tap
 4.1 - 8.0 SFE's requires a 2-inch tap
 8.1 - 16.0 SFE's requires a 3-inch tap