



Landscape/Irrigation Worksheet

Project Name: SP20-081 New Horizon Daycare Site Plan

Landscape/Irrigation Tap address (physical location of tap) SW Corner of the parking lot

Landscape Area	High Water TURF (6,000sf = 1 SFE)	Low Water Native Grass and Spray Shrubs & Perennials (10,000sf = 1 SFE)	Drip Irrigated area (20,000sf = 1 SFE)	Sub-Total of PWSD one Non-Irrigated area (calculated) Areas SFE per 6000		SFE Requirement (Sub-Total Calculation divided by 6000 = requirement)
Area #1	7,068 sf x 1 = 7,068	5,881 sf x .6 = 3,528.6	<u>0</u> sf x .3 = <u>0</u>	5,038 sf x 0 = <u>0</u>	10,596.6 sf 6,000	1.8 SFE's

Worksheet Completed by: Virginia Torzewski  
 Company: SEH  
 Address: 3535 Vadnais Center Drive, St. Paul MN 55110-5196  
 Phone #: (507) 358-5046

Owner/Developer: New Horizon Academy  
 Attn: \_\_\_\_\_  
 Billing Address: \_\_\_\_\_  
 Phone #: \_\_\_\_\_

**ET Controller (with Rain Sensor)**

Manufacturer	
Model number	

**Tap Size Requirements:**  
 0 - 1 SFE's requires a 3/4-inch tap  
 1.1 - 2.0 SFE's requires a 1-inch tap  
 2.1 - 4.0 SFE's requires a 1 1/2-inch tap  
 4.1 - 7.0 SFE's requires a 2-inch tap  
 7.1 - 16.0 SFE's requires a 3-inch tap