

MAINTENANCE ELIGIBILITY PROGRAM (MEP)

MHFD Referral Review Comments

For Internal MHFD Use Only.	
MEP ID:	105575
Submittal ID:	10007379
MEP Phase:	Referral

Date: November 15, 2021
To: **Town Of Parker**
Via email
RE: MHFD Referral Review Comments

Project Name:	Compark Village South F1 Amd 2 Multi-family
Location:	West of E-470 at Happy Canyon Creek
Drainageway:	Happy Canyon Creek

This letter is in response to the request for our comments concerning the referenced project. We have reviewed this proposal only as it relates to maintenance eligibility of major drainage features, in this case:

- No applicable

While there are no proposed features eligible for maintenance, with regards to the slope stability we have the following comments to offer:

- 1) The proposed tie in grading directly south of building 5 is creating a small swale, consider what stabilization will be needed to prevent erosion from the channelized flow.

We appreciate the opportunity to review this proposal. Please feel free to contact me with any questions or concerns.

Sincerely,

A handwritten signature in cursive script that reads 'Laura Hinds'.

Laura Hinds, P.E
Project Engineer
Mile High Flood District

