

## Single-phase Pad Mounted Equipment

- Single-phase pad mounted equipment shall have a minimum of 1'-6" of clear working space on the sides and rear of the equipment, and 10' in front of the equipment.

PLAN VIEW OF SINGLE-PHASE PAD MOUNTED EQUIPMENT  
WORKING SPACE AND LANDSCAPING CLEARANCES

