



MOUNTING HARDWARE ACCESSORIES			
QTY	Description	CAT Logic	Finish
9	OSQ-Direct Arm Mount	OSQ-DABZ	
2	OSQ-Adjustable Arm Mount	OSQ-AABZ	
-	Single Side Mount Bracket	SQ-SP-D	
-	Twin Side Mount Bracket	(2) SQ-SP-D	
-	NTF-Knuckle Mount	NTF-KN-BZ	SVHVL (Silver)
-	Tenon Square - 4 at 90 deg	PB-4A4	BKHVL (Black)
-	Single Round Tenon Reducer	79918	BZHVL (Bronze)
-	Tenon Round - 2 at 180 deg	79918 & 79952	GRHVL
-	Tenon Round - 3 at 180 deg	79918 & 79954	WHHVL (White)
-	NTF-Trunnion Mount	NTX-TR-BZ	SV
2	CP Beauty plate	RS9063-WT	BK
2	Wall Mount Bracket	WM-SP-D	BZ
-	Vertical Tenon Mount Bracket	SP-TR-D	GR
-	OSQ HO-Direct Arm Mount	OSQ-HO-DA-BZ	WH
-	OSQ HO-Adjustable Arm Mount	OSQ-HO-AABZ	
-	Goof Ring-8"	GRRRC8RPTWT	
-	Goof Ring-10"	GRRRC10RPTWT	
-	Goof Ring-12"	GRRRC12RPTWT	
2	Goof Ring-6"	GRRRC6RPTWT	
-	2 X 2 Surface Mount	C-ACC-PSMK22	
-	NTF-Adjustable Arm Mount	NTX-AA-BZ	
-	Spring-Mount Ceiling Cover Plate	CP9000	
-	Single Square tenon Reducer	79912	
-	Twin Square tenon Reducer	79944A	
-	Triple Square tenon Reducer	79945A	

CAT #	Voltage
0	120V-277V
1	120V
2	208V
4	277V
5	480V
H	347-480V

INCANDESCENT, PAR, T8 and T12 Standard Output LED Solutions		
Qty	Existing Fixture	Solution
-	2 - 4 T8 Lamp	(2) LED118D78G4840
-	A19	LED6DA19840
-	4 T8 Bulb	LED118D78G4840
-	A19 Enclosed	LED150A21840

Wells Fargo Exterior Lighting Spec V1			
Exterior ATM / Night Depositors	5' circle	Spec - H	Spec - NH
ATM	10 fc	10 fc	10 fc
*Minimum FC levels	50' circle	2 fc	1 fc
WF Parking areas within 60'	2 fc	1 fc	1 fc
If within 10' of a corner:	40' unobstructed along wall (For 50' calc)	2 fc	1 fc
Night Depositors	5' circle	10 fc	10 fc
*Minimum FC levels	50' circle	2 fc	1 fc
If within 10' of a corner:	40' unobstructed along wall	2 fc	1 fc
Vestibule Door with ATM	5' circle	10 fc	10 fc
*Minimum FC levels	50' circle	2 fc	1 fc
WF Parking areas within 60'	2 fc	1 fc	1 fc
If within 10' of a corner:	40' unobstructed along wall (For 50' Calc)	2 fc	1 fc
Inside the vestibule doors with ATMND	All over the Vestibule	10 fc	10 fc
*Minimum FC levels			

Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min	Meter Type
AHD_5'	Illuminance	Fc	131.82	165.5	82.4	1.60	2.01	Horizontal
AHD_50'	Illuminance	Fc	27.04	109.3	1.5	18.03	72.87	Horizontal
AHD_60'	Illuminance	Fc	14.33	65.3	1.8	7.96	36.28	Horizontal
ATM1_5'	Illuminance	Fc	69.30	95.6	21.9	3.16	4.37	Horizontal
ATM1_50'	Illuminance	Fc	20.95	79.4	1.5	13.97	52.93	Horizontal
ATM1_60'	Illuminance	Fc	20.43	114.5	2.4	8.51	47.71	Horizontal
ATM2_5'	Illuminance	Fc	48.72	64.0	25.9	1.88	2.47	Horizontal
ATM2_50'	Illuminance	Fc	11.06	46.4	1.9	5.82	24.42	Horizontal
ATM2_60'	Illuminance	Fc	6.38	33.5	1.7	3.75	19.71	Horizontal
Parking Layout	Illuminance	Fc	8.18	88.4	0.0	N.A.	N.A.	Horizontal


Symbol	Qty	Label	Description	Arr. Watts	Arr. Lum. Lumens	LLF
[Symbol]	12	C-WP-B-10L	C-WP-B-RDC-10L-40K-DB	76.4	10600	0.880
[Symbol]	14	RUL48	RUL48A0W40LB	42	4301	0.880
[Symbol]	7	LED Can	For Reference Only	13	1050	0.880
[Symbol]	2	OSQ-A-4ME-53W	OSQ-A-NM-4ME-Z-40K-UL-BZ	53	6896	0.880
[Symbol]	2	NEW_C-CP-7L	C-CP-C-SQ-7L-40K-WH	54.5	6880	0.880
[Symbol]	2	CDR6	CDR6-ALS-8ACK-10VS-WH-LNV	13	1050	0.880
[Symbol]	2	C-CP-7L	C-CP-C-SQ-7L-40K-WH	54.5	6880	0.880
[Symbol]	2	2-OSQ-A-4ME-166W	2-OSQ-A-NM-4ME-T-40K-UL-BZ	332	43804	0.880
[Symbol]	1	OSQ-A-4ME-166W	OSQ-A-NM-4ME-T-40K-UL-BZ	166	21902	0.880
[Symbol]	1	New_OSQ-A-4ME-215W	OSQ-A-NM-4ME-U-40K-UL-BZ	214.51	27524	0.880
[Symbol]	1	New_OSQ-A-4ME-166W	OSQ-A-NM-4ME-T-40K-UL-BZ	166	21902	0.880
[Symbol]	1	NEW_C-WP-B-10L	C-WP-B-RDC-10L-40K-DB	76.4	10600	0.880
[Symbol]	1	LED Strip	For Reference Only	28.5	4115	0.880
[Symbol]	1	2-OSQ-A-4ME-53W	2-OSQ-A-NM-4ME-Z-40K-UL-BZ	106	13792	0.880
[Symbol]	1	2-Non WellsFargo Pole	For Reference only	106	13792	0.880

Site Notes:

- New 2 Qty's of Area lights, New 2 Qty's of Canopies and New 1 Qty of Wallpack are proposed for achieving the compliance and Street View.
- All fixture are taken as per Audit Image and Street View.
- LED Fixtures and Non WellsFargo Fixtures are captured for reference only.
- Tree trimming are required marked with a Red polygon.



THIS IS A D SIZE SHEET. THE NOTED SCALE IS NOT VALID IF PRINTED AS ANY OTHER SIZE.


Southern Lighting Source
 800 Battery Avenue SE Suite 410
 Atlanta, GA

Designer: SS
 Date: 10-09-2021
 SLS Drawing #: WF # 120751 - Parker 10900 S PARKER RD PARKER CO. GA

WF # 120751 - Parker
 10900 S PARKER RD PARKER CO
 Horizontal and Vertical FC indicated
 Values at maintained output

Page 1 of 3

Calculator light levels are based on specific information that has been supplied to SLS. Any differences in luminaire installation, light area geometry and obstructions in the light area may produce different results from the predicted values. Normal tolerances of voltage, lamp output, and ballast and luminaire manufacture will affect results.

Ref: IES LM-61-1986 Identifying Operating Factors for HID Luminaires

Southern Lighting Source
800 Battery Avenue SE Suite 410
Atlanta, GA 30339

SLS Drawing #: WF # 120751 - Parker 10900 S PARKER RD PARKER CO. GA

