

Reviewed for code compliance


03/26/2024



RFCC

Approved:
03/27/2024

Planning Approval:
J. Miller



Must provide clear unobstructed path from all building Exit Doors and install fence gates directly in the same travel path. These fence gates must have a sign which states " This door/gate to remain unlocked when this space is occupied", with 1" letters. You may need to staff these areas since the gates are required to be open during business hours. See red-lined plan. There may be other locations however, this issue will be field verified during inspection once all fencing has been installed. Place an minimum 2A-10BC Fire Extinguisher (FE) by each gate opening.

Please call to schedule the inspection when ready.
303.841.1970 and ask for Jeff Miller,
Randy Sale, or Jon Nelson.

City of Parker. This year as in years past, Costco is planning to do a large live plant and flower display in our vestibule area. This seasonal promotion will run the duration of about 6 weeks. In an effort to prevent theft and conceal the merchandise, we will assemble a fence of 154 feet that will be placed 7 feet away from the outside wall of our building. With the fence assembled, an 8 foot walkway will still be available for pedestrians.