

Traffic & Safety

Region 1

2829 W Howard Place, 2nd Floor
Denver, Colorado 80204



COLORADO
Department of Transportation
Region 1

Project Name: SP24-128 Black Rock Coffee Parker

Print Date: 10/15/2025

Highway: 083

Mile Marker: 56.809

A comment response letter is REQUIRED along with the next submittal.

Review POC: Tripple, Joseph

Hydraulics Comments:

I have reviewed the attached drainage memo

There is no mention of historical and developed flows, and the plan to detain the developed flows, needs to state clearly that there will be no negative drainage/sediment impact to SH83 due to this development

A site visit with the consultant to take a closer look at the existing drainage features is highly recommended
Samer 9-8-2025. Samer 9-15-2025 Samer 10-13-2025