

## **MEP REVISION NARRATIVE**

Project Name: 7 Brew – Parker, CO  
Revision Title: Rev. 1

Date: 12/05/2025  
Project Number: 040022.014

### **SCOPE SUMMARY:**

City Comments.

### **ELECTRICAL**

1. SE1.1 – PHOTOMETRIC SITE PLAN
  - a. 1/SE1.1 – SITE PHOTOMETRICS
    - i. Deleted (20) B fixtures in Canopy per City Comments.
    - ii. Revised location of (12) B fixtures at Canopy per city comments.
    - iii. Added (2) SL3 HS P2 fixtures in Drive and sidewalk calc zone to comply with 6:1 uniformity ratio per city comments.
    - iv. Deleted (1) SL5 fixture and reduced lumen output to comply with 6:1 uniformity ratio per city comments.
    - v. Revised (1) SL3 location/orientation to comply with 6:1 uniformity ratio per city comments.
    - vi. Added dimensions at all Parking Lot Pole Fixtures located around the perimeter per city comments.
  - b. LUMINAIRE SCHEDULE
    - i. Revised quantity for fixtures B, SL3 HS P2, and SL5.
    - ii. Revised fixture type SL5 per city comments.
    - iii. Added fixture type SL3 per city comments.
  - c. CALCULATION SUMMARY
    - i. Revised per City Comments.