



Date: July 14, 2020
To: *Via email*
RE: MHFD Referral Review Comments

Project Name:	Compark South Belford Ave
Location:	South of E470 at Green Acres Tributary
Drainageway:	Green Acres Tributary

This letter is in response to the June 10, 2020 review comments.

We have the following comments to offer:

- 1) Please label the Q, V, and Fr on the profiles for FES 1-6 and FES 1-10.
The Q, v and Fr have been added to the profile for FES 1-10. It was already shown for FES 1-6.
- 2) Please provide the Green Acres Trib. water surface elevation on the profiles for all three eligible features.
The 100 yr water surface elevation has been added to the profiles for the maintenance eligible drainage features, i.e. FES 1-4, FES 1-6 and FES 1-10. The elevations were taken from "Final Drainage Report for Green Acres Tributary Project", prepared by RESPEC, dated June 5, 2020.

We appreciate the opportunity to review this proposal. Please feel free to contact me with any questions or concerns.

Sincerely,

Manhard Consulting

Amie S. Drucker, PE
Project Manager