

MAINTENANCE ELIGIBILITY PROGRAM (MEP)

MHFD Referral Review Comments

For Internal MHFD Use Only.	
MEP ID:	106406
Submittal ID:	10004520
MEP Phase:	Referral

Date: June 10, 2020

To:

Via email

RE: MHFD Referral Review Comments

Project Name:	Compark South Belford Ave
Location:	South of E470 at Green Acres Tributary
Drainageway:	Green Acres Tributary

This letter is in response to the request for our comments concerning the referenced project. We have reviewed this proposal only as it relates to maintenance eligibility of major drainage features, in this case:

- Outfall FES 1-4 (36" FES)
- Outfall FES 1-6 (24" FES)
- Pond Outfall FES 1-10 (36" FES)

We have the following comments to offer:

- 1) Please label the Q, V, and Fr on the profiles for FES 1-6 and FES 1-10.
- 2) Please provide the Green Acres Trib. water surface elevation on the profiles for all three eligible features.

We appreciate the opportunity to review this proposal. Please feel free to contact me with any questions or concerns.

Sincerely,



Kurt Bauer, P.E., CFM

Project Manager, Watershed Services
Mile High Flood District
KBB/brz