

March 12, 2018

Ms. Stacey Nerger
Town of Parker
20120 E Mainstreet
Parker CO 80138

Re: Trails at Crowfoot Filing #2 Project #SUB17-041
Final Plat 3rd Referral
PWSD Project #2017-071

Dear Ms. Nerger:

Thank you for forwarding the referral request for the above mentioned project. After a review of the documents submitted, the Parker Water & Sanitation District has the following comments:

- On sheet 4 the intermediate plat form will not be required for MH-5, please remove callout.
- On sheet 7 callout the storm line crossing just to the South of MH-35 in the profile.
- PWSD has no further design comments for filing 2.
- SIA, Letter of Credit, Filing #1 PWSD approval, and mylars signed by a Town of Parker life safety official are required to be submitted before PWSD approval.

Please let us know if you have any question on the above comments. We look forward to the final submittal on this project.

Sincerely,
Parker Water & Sanitation District


Drayton Sanderson
Engineering Technician

